



Testing. Advising. Assuring.

**EWFA CERTIFICATE OF ASSESSMENT**      **CERTIFICATE No : SFC 26371-00**      **Page 1 of 1**

Report Sponsor	Certificate Issue Date	Product Name
Coopers Fire Pty Ltd 21B, 1-3 Endeavour Road Caringbah, NSW, 2229	14/05/2013	<b>FireMaster Curtain with Wall Wetting Deluge Sprinklers</b>

Assessment Report Reference	Test Methods	Report Issue Date	Report Validity Date
EWFA 26371-00	AS1530.4-2005	4/04/2013	30/04/2018

**Introduction**

The element of construction described below was assessed by this laboratory on behalf of the report sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report(s) or Regulatory Information Reports for more information.

**Description of Assessed Products**

The test specimen is a FireMaster fire curtain protected with wall wetting deluge sprinklers installed on one side or both sides (depends on designs) tested in accordance with AS1530.4-2005 and assessed in accordance with AS1905.2-2005. For a detailed description of assessed construction refer to referenced report.

**Performance of Assessed Products**

Table 1: Single Barrel Designs up to 30m wide			Table 2: Multiple Barrel Designs up to 30m wide			
Max Opening Height	FRL	Radiation (with sprinkler system on unexposed side)	Max Opening Height	Min. Curtain Overlap	FRL	Radiation (with sprinkler system on unexposed side)
4m	-/120/120 One direction only	<10 kW/m <sup>2</sup>	4m	600mm	-/120/120 One direction only	<10 kW/m <sup>2</sup>
4m	-/120/120 from either direction	<10 kW/m <sup>2</sup>	4m	600mm	-/120/120 from either direction	<10 kW/m <sup>2</sup>

For a detailed description of assessed construction refer to referenced report.

For a detailed description of assessed construction refer to referenced report.

**Conditions/Validity**

- THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.
- Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.
- The results of these fire tests may be used to assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all conditions.

<b>TESTING AUTHORITY</b>	Exova Warringtonfire Aus Pty Ltd	
<b>Address</b>	Suite 2002a, Level 20, 44 Market Street, Sydney NSW 2000, Australia	
<b>Phone / Fax</b>	+61 (0)2 8270 7600 / +61 (0)2 9299 6076	
<b>ABN</b>	81 050 241 524	
<b>Email / Home Page</b>	<a href="http://www.exova.com">www.exova.com</a>	
<b>Authorisation</b>	Prepared By:  S. Hu	Reviewed By:  K. G. Nicholls