

SPECIFICATION
FIREMASTER® INSUL8
ACTIVE FIRE CURTAIN BARRIER ASSEMBLIES

In accordance with:

BS EN 1634-1
BS EN 13501-2

Period of Fire Resistance:

240 minutes (4 hours) integrity

Period of Radiation:

240 minutes <15kW/m²

Period of Insulation (I1):

90 minutes (1½ hours)

Period of Insulation (I2):

90 minutes (1½ hours)

Classification:

E240 EW240 EI₁90 EI₂90

Certification:

Complete barrier assemblies are certified by an independent accredited certification body operating to ISO/IEC 17065:2012.

Complete barrier assemblies are certified with an independent accredited certification body operating an accredited UKAS scheme for installation, commissioning and servicing.

Product Name and Model:

FireMaster® Insul8 active fire curtain barrier assemblies

General description:

An electrically operated FireMaster® Insul8 active fire curtain barrier assembly used to form a virtually continuous barrier as a fire separating element.

FireMaster® Insul8 active fire curtain barrier assemblies comprise a composite fabric wound on to a steel roller, powered by an internal 24V dc electric motor, enclosed within a 1.2 mm steel box.

A weight bar is fitted to the inside of the curtain providing tension to the curtain with sufficient weight for the curtain to 'fail-safe by gravity'.

The 24V motor contains an electromagnetic brake to arrest motion of the curtain when in the open position.

SPECIFICATION

FIREMASTER® INSUL8

ACTIVE FIRE CURTAIN BARRIER ASSEMBLIES

FireMaster® Insul8 active fire curtain barrier assemblies have been tested to the requirements of BS EN 1634-1:2014 for 'Fire Resistance' (240 minutes integrity).

FireMaster® Insul8 active fire curtain barrier assemblies have been tested to the requirements of BS EN 1634-1:2014 for 'Radiant Heat Flux' (240 minutes).

FireMaster® Insul8 active fire curtain barrier assemblies have been tested to the requirements of BS EN 1634-1:2014 for 'Insulation' EI₁ and EI₂ (90 minutes).

Operation:

FireMaster® Insul8 active fire curtain barrier assemblies commence movement upon initiation of alarm or power or system failure, and fully deploy to the fire operational position via gravity failsafe within the range of velocities of 0.06 m/s to 0.15 m/s using the unique VarioSpeed™ function.

Operating speeds are site adjustable without altering the bottom bar mass. Speeds may be dictated by those authorities having jurisdiction for 'safety in use' according to the location, nature or function of each unit.

In the event of a mains supply power failure, the curtain is retained in the open position for a pre-determined period (nominally 30 minutes), using battery back-up power. At the end of the period, the barrier assembly will deploy via gravity failsafe.

Optional Extras:

- Voice warning:
Audio or spoken multi message facility when mains or emergency power is available.
- Beam protection and obstruction warning:
A beam detector, with delay timer which will sound in the event of any obstruction being placed in the barrier drop line when mains or emergency power is available.
- Visual alert system:
Light warning system when mains or emergency power is available.
- Split drop delay:
To partially deploy to pre-determined level to permit escape, and initial smoke containment. After delay fully deploys to its fire operational position when mains, or emergency power is available.
- Emergency retract:
Touch button retract facility for multi-escape and emergency service ingress/egress when mains or emergency power is available.

Manufacturers:

Subject to compliance with all requirements set out in this specification, manufacturers offering products may be incorporated into the work are limited to the following:

Coopers Fire Limited, Ignis House, Houghton Avenue, Waterlooville Hampshire, PO7 3DU, United Kingdom. Tel +44 (0)23 9245 4405

Email: sales@coopersfire.com, Web: <http://www.coopersfire.com>

SPECIFICATION
FIREMASTER® INSUL8
ACTIVE FIRE CURTAIN BARRIER ASSEMBLIES

Warranty:

The manufacturer shall submit a written warranty for a period of one (1) year. If any part of the works of this section, including design, fabrication or installation are sublet to any party, such party shall provide a collateral warranty equivalent to the warranty.

Product certification, performance and/ or testing:

- FireMaster® Insul8 active fire curtain barrier assemblies are certified by an independent accredited certification body operating to ISO/IEC 17065:2012.
- FireMaster® Insul8 active fire curtain barrier assemblies have been tested for fire resistance to BS EN 1634-1. The Barrier assembly achieved 240 minutes Integrity, 240 minutes Radiation and 90 minutes Insulation (EI₁ and EI₂).
- FireMaster® Insul8 active fire curtain barrier assemblies have been tested for gravity fail-safe as required by BS 8524-1
- Motor(s) used within FireMaster® Insul8 active fire curtain barrier assemblies have been cycle tested for 50,000 operations (C3)
- Motor(s) used within FireMaster® Insul8 active fire curtain barrier assemblies have been tested for operation at temperatures of 400 °C as required by BS 8524-1

Approving standards:

The following standards apply to this product:

- BS EN 1634-1:2008, Fire resistance and smoke control tests for door, shutter and, openable window assemblies and elements of building hardware. Fire resistance tests for doors, shutters and openable windows
- BS EN 1363-1:2012, Fire resistance tests – Part 1: General requirements
- BS EN 1363-2:1999, Fire resistance tests – Part 2: Alternative and additional procedures
- BS EN 13501-2:2007+A1, Fire classification of construction products and building elements. Classification using data from fire resistance tests, excluding ventilation services rating
- BS EN ISO 9001:2015, Quality management system
- BS EN ISO 14001:2015, Environmental management system
- BS EN ISO 45001: 2018; Occupational Health and Safety Management